

EU Type-Examination Certificate



according to Regulation (EU) 2016/426 Article 14, section 2.
on appliances burning gaseous fuels – Module B – production type

Certificate No.: MB 69261119 0001 **PIN:** 1008 CT 3271
Test Report No.: 28247713 001
Certificate Holder: Pakole Trade Kft.
H - 8000 Székesfehérvár, Börgöndi út 8 - 10.
Manufacturer: Pakole Trade Kft.
H - 8000 Székesfehérvár, Börgöndi út 8 - 10.
Product: Group: Heating and air conditioning appliances (3300)
Gas-fired overhead radiant tube heaters (3311)
Identification: Models:
ZENIT..., OMEGA..., Infragaz IGT...;
ZENIT 70+..., ZENIT 80+...
See details in Annex I.
Tested according to: EN 416-1:2009
Countries of destination: AT, BE, BY, CY, CZ, DK, GB, EE, FI, FR, GR, NL, IE, PL,
LV, LT, LU, HU, DE, NO, IT, PT, RO, ES, CH, SE, SK, SI,
TR, UA, RU, BA, BG, MD, RS, HR
Valid until 14.12.2028

This EU type-examination certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the essential requirements of Annex I of the Regulation. The Certificate holder is entitled to use this certificate in connection with the EU declaration of conformity in accordance with the Regulation. This certificate does not imply assessment of the series production of the product and does not permit the use of a TÜV Rheinland mark of conformity. This certificate itself does not permit the affixing of CE marking followed by the identification number of the notified body.

Date of issue:
Budapest, 14.12.2018

Certification Body

Gergely Bakos
1. Notified Body 1008

TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu
Notified under No. 1008 in EU

The CE marking may be used if all relevant and effective EC directives are complied with.

Annex I to certificate No. MB 69261119 0001

Page 1/2

PIN: 1008 CT 3271

Destination countries	Appliance categories
AT	II _{2H} (20)3B/P(50)
BG	II _{2H} (20)3B/P(30)
BY	II _{2H} (20)3B/P(30, 50)
CY	I _{2H} (20)
CZ	II _{2H} (20)3P(37)
DK	II _{2H} (20)3B/P(30)
GB	I _{2H} (20), II _{2H} (20)3P(37, 50)
EE	II _{2H} (20)3B/P(30)
FI	II _{2H} (20)3B/P(30)
GR	I _{2H} (20), II _{2H} (20)3P(37)
NL	I _{3B} /P(30), I _{3P} (50)
IE	I _{2H} (20), II _{2H} (20)3P(37)
PL	II _{2E} (20)3P(37), II _{2E} (20)3B/P(30)
LV	II _{2H} (20)3B/P(30)
LT	II _{2H} (20)3B/P(30)
LU	I _{2E} (20)
HU	II _{2HS} (25)3B/P(30)
DE	II _{2ELL} (20)3B/P(50), II _{2ELL} (20)3P(50)
NO	II _{2H} (20)3B/P(30)
IT	I _{2H} (20)
PT	I _{2H} (20), II _{2H} (20)3P(37)
RO	II _{2H} (20)3B/P(30)
ES	I _{2H} (20), II _{2H} (20)3P(37)
CH	II _{2H} (20)3B/P(50), I _{2H} (20), II _{2H} (20)3P(37)
SE	II _{2H} (20)3B/P(30)
SK	II _{2H} (20)3B/P(30), II _{2H} (20)3P(37, 50)
SI	II _{2H} (20)3B/P(30), II _{2H} (20)3P(37)
TR	I _{2H} (20), I _{3P} (37), I _{3B} /P(20)
UA, RU, BA, MD	II _{2H} (20)3B/P(30, 50)
RS, HR	II _{2H} (20)3B/P(50)

Models: ZENIT-..., OMEGA-..., Infragaz IGT-...	Nominal heat input (kW)
... 12	12
... 14	14
... 16	16
... 18	18
... 20	20
... 22	22
... 24	24
... 26	26
... 28	28
... 30	30
... 32	32
... 34	34
... 36	36
... 38	38
... 40	40
... 42	42
... 44	44
... 46	46
... 48	48
... 50	50
... 52	52
... 54	54
... 56	56
... 58	58

Flue type:

Flue pipes diameter:

Electrical supply:

Flue pipe brands:

B₂₃, B₅₃, C₁₃, C₃₃, C₅₃, C₈₃

Models from ...12 to ...48-ig Ø150/Ø100 mm

Models from ...50 Ø200/Ø150

AC 230 V 50 Hz

LIM-MONT ECO DIM DW, LIM-MONT ECO DIM DE.

Certification Body

Date of issue:

Budapest, 14.12.2018



Gergely Bakos

TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu

Annex I to certificate No. MB 69261119 0001

Page 2/2

PIN: 1008 CT 3271

Destination countries	Appliance categories
AT	II _{2H} (20)3B/P(50)
BG	II _{2H} (20)3B/P(30)
BY	II _{2H} (20)3B/P(30, 50)
CY	I _{2H} (20)
CZ	II _{2H} (20)3P(37)
DK	II _{2H} (20)3B/P(30)
GB	I _{2H} (20), II _{2H} (20)3P(37, 50)
EE	II _{2H} (20)3B/P(30)
FI	II _{2H} (20)3B/P(30)
GR	I _{2H} (20), II _{2H} (20)3P(37)
NL	I _{3B} /P(30), I _{3P} (50)
IE	I _{2H} (20), II _{2H} (20)3P(37)
PL	II _{2E} (20)3P(37), II _{2E} (20)3B/P(30)
LV	II _{2H} (20)3B/P(30)
LT	II _{2H} (20)3B/P(30)
LU	I _{2E} (20)
HU	II _{2HS} (25)3B/P(30)
DE	II _{2ELL} (20)3B/P(50), II _{2ELL} (20)3P(50)
NO	II _{2H} (20)3B/P(30)
IT	I _{2H} (20)
PT	I _{2H} (20), II _{2H} (20)3P(37)
RO	II _{2H} (20)3B/P(30)
ES	I _{2H} (20), II _{2H} (20)3P(37)
CH	II _{2H} (20)3B/P(50), I _{2H} (20), II _{2H} (20)3P(37)
SE	II _{2H} (20)3B/P(30)
SK	II _{2H} (20)3B/P(30), II _{2H} (20)3P(37, 50)
SI	II _{2H} (20)3B/P(30), II _{2H} (20)3P(37)
TR	I _{2H} (20), I _{3P} (37), I _{3B} /P(20)
UA, RU, BA, MD	II _{2H} (20)3B/P(30, 50)
RS, HR	II _{2H} (20)3B/P(50)

Models:	Nominal heat input (kW)
ZENIT 70+ ...	
/12/L.. OR U..	12
/14/L.. OR U..	14
/16/L.. OR U..	16
/18/L.. OR U..	18
/20/L.. OR U..	20
/22/L.. OR U..	22
/24/L.. OR U..	24
/26/L.. OR U..	26
/28/L.. OR U..	28
/30/L.. OR U..	30
/32/L.. OR U..	32
/34/L.. OR U..	34
/36/L.. OR U..	36
/38/L.. OR U..	38
/40/L.. OR U..	40
/42/L.. OR U..	42
/44/L.. OR U..	44
/46/L.. OR U..	46
/48/L.. OR U..	48
ZENIT 80+ ...	
/14/L.. OR U..	14
/16/L.. OR U..	16
/18/L.. OR U..	18
/20/L.. OR U..	20
/22/L.. OR U..	22
/24/L.. OR U..	24
/26/L.. OR U..	26
/28/L.. OR U..	28
/30/L.. OR U..	30
/32/L.. OR U..	32
/34/L.. OR U..	34
/36/L.. OR U..	36
/38/L.. OR U..	38
/40/L.. OR U..	40
/42/L.. OR U..	42

Sample of models:

ZENIT 70+/14/L6; ZENIT 70+/14/U3
ZENIT 80+/14/L9; ZENIT 80+/14/U4,5

Flue type:

B₂₃, B₅₃, C₁₃, C₃₃, C₅₃, C₈₃

Flue pipes diameter:

Ø150/Ø100 mm

Flue pipe brands:

LIM-MONT ECO DIM DW, LIM-MONT ECO DIM DE.

Date of issue:

Budapest, 14.12.2018

Certification Body


Gergely Bakos

TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu